

Report

Function test liquid based leak detector LAS

Site of facility

Company

First name / last name

Street

Postcode / city

Product LAS 24, 39, 72 and 230

Approval: Technical Approval of the German Institute for Civil Engineering (DIBt) Z-65.24-381

- Checklist**
- Results of visual inspection of the system: Installation as per instructions, no visible damage.
 - The system was tested by opening the test valve.
 - The leak detection fluid escaped at a flow rate of at least 0.5 l/min.
 - The level of the leak detection fluid is correct.

Notes

Date of test:

Specialised company (as per WHG (AwSV)):

Company

First name / last name

Street

Postcode / city

Signature/stamp